



ADDENDUM NO. 1

TO: All Planholders

FROM: J. Brent Gruber, P.E.
Project Engineer

DATE: November 18, 2011

RE: City of Fairview
Main Street Sanitary Sewer Rehabilitation Project
WE Job No. 1191D

Notice is hereby given to prospective bidders that the Contract Documents have been amended as follows:

- **A copy of this addendum is available for download at the ENGINEER'S website:** <http://walliseng.net/login/>.

ITEM 1:

PART I – BIDDING DOCUMENTS, BID PROPOSAL FORM, Bid Item 6 - Pipe Bursting and HDPE Liner, 8-Inch and Bid Item 7 - Pipe Bursting and HDPE Liner, 4-Inch and Cleanout, Note these bid items include payment for sewer mainline and lateral pipe bursting regardless of sewer depth (All Depths).

ITEM 2:

PART I – BIDDING DOCUMENTS, BID PROPOSAL FORM, Bid Item 13 – Reconnect Existing DI Lateral to New Sewer Pipe and Cleanout (All Depths), Note this bid item includes payment both ductile iron and cast iron lateral reconnection in accordance with Section 00490.

ITEM 3:

PART IV – SPECIAL PROVISIONS, SECTION 00410 – PIPE LINING – 00410.90 Payment, Add with the following sentence to the first paragraph:

“Replacement of existing striping and pavement markings impacted by the pipe lining operation shall be incidental to the pipe lining bid price.”

ITEM 4:

PART IV – SPECIAL PROVISIONS, SECTION 00744 – MHMAC PAVEMENT – 00744.49 Compaction, Replace the next to last sentence with the following:

“Perform a minimum of two (2) asphalt concrete trench patch density tests per block.”

ITEM 5:

PART V – CONTRACT DRAWINGS, SHEET C2, GENERAL NOTES, LEGEND & TYPICAL DETAILS, General Notes, Add the following note: “Contractor shall coordinate with Fairview Elementary School construction staging, traffic control and temporary road closures to avoid disruption to school bus routing and activities.”

ITEM 6:

PART V – CONTRACT DRAWINGS, SHEET C10, MISCELLANEOUS DETAILS, Detail 3, Add the following note: “Sawcut, removal and disposal of ductile iron or cast iron lateral pipe shall be incidental to the “Reconnect Existing DI Lateral to New Sewer Pipe and Cleanout” bid item.”

All bidders shall acknowledge receipt of this addendum by dating and signing the appropriate line in the Bid Proposal Form submitted with their bid.